

Clarification#2: Procurement of Supply, Delivery, and Installation of Air Conditioners for Central and Field Offices.

(MCA-N/PM/SH/054)

16th August 2022

Questions and Answers:

#	Questions	Answer
1	<p>In Annex 1- Quotation Submission Form Line Item A, S. No 2 is “1.5 ton (18000 BTU) Capacity AC Including a 3 KVA Single Phase Power Stabilizer”.</p> <p>In our experience 3KVA single phase power stabilizer is not sufficient for 1.5-ton Air Conditioner. It needs at least 4KVA power stabilizer. Hence, can we quote for 4KVA single phase power stabilizer instead?</p>	<p>Please quote your price for the line items and capacity/configuration as requested in the RFQ respectively.</p>
2	<p>In Annex 1- Quotation Submission Form Line Item A, S. No 1 is “1 ton (12000 BTU) Capacity AC Including a 3 KVA Single Phase Power Stabilizer”.</p> <p>Can we supply for 4 KVA Single phase Stabilizer along with 1 ton Air Conditioner with the same price?</p>	<p>Yes, however the Bidders shall quote for at least the minimum technical requirements as requested in the RFQ.</p>
3	<p>Can we replace the Brand Product as mentioned on our submitted quotation with similar specifications?</p>	<p>Bidders may quote any brand that meets or equivalent to the technical specifications of requested goods during its submission of quotation.</p> <p>However, once the quotation is submitted, the bidders are not allowed to change the brand. This is as per our procurement compliance, so, bidders are not allowed to change their proposed brands under normal business scenario.</p>