



Procurement of Plant Design, Supply, Delivery, Installation, Testing and Commissioning of
Lot 1: Lapsiphedhi-Ratmate-New Hetauda 400kV D/C Transmission Line
Lot 2: Ratmate-New Damauli 400kV D/C Transmission Line
Lot 3: New Damauli-New Butwal 400kV D/C Transmission Line (Base) And New Butwal -Nepal/India Border 400kV D/C Transmission Line (Option)

ADDENDUM #7

Issued on: 30 March 2023

This Addendum No. 7 modifies respective portions of the Bidding Document issued on 28 November 2022 and amended through Addendum No. 1 on 4 January 2023, Addendum No. 2 on 14 February 2023, Addendum No. 3 on 27 February 2023, Addendum No. 4 on 3 March 2023, Addendum No. 5 on 15 March 2023 and Addendum No. 6 on 30 March 2023. The changes, as indicated below, are effective on the date of issue of this Addendum.

Except as expressly amended by this Addendum, all other terms and conditions of the Bidding Document - issued on 28 November 2022 and amended through Addendum No. 1 on 4 January 2023, Addendum No. 2 on 14 February 2023, Addendum No. 3 on 27 February 2023, Addendum No. 4 on 3 March 2023, Addendum No. 5 on 15 March 2023 and Addendum No. 6 on 30 March 2023 remains unchanged and shall remain in full force and effect in accordance with their terms.

SN	Pages/Paragraph	Amendments
1	Part 1, Page 84, Section III: Qualification and Evaluation Criteria, Subcontractors / Manufacturers, Insulators, Minimum criteria to be met	<p>The insulator manufacturer shall have been in its business for the last ten (10) years. It shall have manufactured and supplied minimum 400,000 disc insulators within the last five (5) years of 160KN rating or as per ANSI 52-8 and above.</p> <p>has been replaced by:</p> <p>The insulator manufacturer shall have been in its business for the last ten (10) years. It shall have manufactured and supplied minimum 100,000 disc insulators of Glass within the last five (5) years.</p>
	Part 2, B1, Annex_B1, 6. Annex	1. The insulator manufacturer shall have been in its business for the last ten (10) years. It shall have manufactured and supplied minimum 400,000 disc insulators within

<p>D_Technical Specifications_Final Design Report-2019-11-08, Annex D Appendix 8 - Insulator Specification Rev 1, Page 3.10 or PDF Page 25 of 54, 3.1 PARAMETERS FOR TENDER DOCUMENT, A. Proof of Experience</p>	<p>the last five (5) years of 160KN rating or as per ANSI 52-8 and above for operating at voltage level equal to or higher than 230kV AC.</p> <ol style="list-style-type: none"> 2. Evidence is to be given by reference lists for the required period of time (showing supplied insulator quantities in pieces, project designation, year of supply). Additionally, a type test report for insulator unit(s) shall be submitted. 3. The references shall clearly mention the name of the transmission line and its operating voltage, month and year of delivery completion and operation: quantities and type of insulators and the name of the utility, addresses and phone number, as well as the name and mail address of a representative of the utility. 4. The Owner has the right to verify the experience and performance of the Supplier by contacting the utilities which issued the submitted performance evidences but also by its own criteria, not limited to these utilities. <p>has been replaced by:</p> <ol style="list-style-type: none"> 1. The insulator manufacturer shall have been in its business for the last ten (10) years. It shall have manufactured and supplied minimum 100,000 disc insulators of 160KN rating or as per ANSI 52-8 and above within the last five (5) years. 2. Evidence is to be given by reference lists for the required period of time (showing supplied insulator quantities in pieces, project designation, year of supply). Additionally, a type test report for insulator unit(s) shall be submitted. 3. The references shall clearly mention the name of the transmission line and its operating voltage, month and year of delivery completion and operation: quantities and type of insulators and the name of the utility, addresses and phone number, as well as the name and mail address of a representative of the utility. 4. The Owner has the right to verify the experience and performance of the Supplier by contacting the utilities which issued the submitted performance evidence but also by its own criteria, not limited to these utilities.
--	--